

VOC Content Test Certificate

Wednesday 24th July 2019

Supplier: Rockstar Sealing System (3 Spray Avenue, Mordialloc, VIC, 3195).

Sample Description: Rockstar – Greenstar Sealer

Date Tested: July 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

| | |
|--|--|
| <p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.2-13.1.1B Green Star Interiors V1.2-12.1.1B</p> | <p align="center">Rockstar - Greenstar Sealer</p> |
| <p align="center">Primers, sealers and prep coats: 65 grams per Litre as VOC content per material</p> | <p align="center">38 gram per Litre as VOC content per material</p> |
| <p align="center"><i>We hereby certify Rockstar – Greenstar Sealer is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc
Consultant

V1907081