

SLIP REPORT

slip report provided by Rockstar Sealing Anti Slip Division.

Wet Pendulum - "P" Rating (AS - Appendix A)

*** Minimum Specimen Size & Quantity**

For tiles or other discreet flooring products (ceramics, stone, carpet tile, vinyl tile/planl) a minimum of five (5) individual specimens being at least 150x150 mm each.
for flooring products that are either a coating system (paint, epoxy, etc), or a sheet type product (vinyl, rubber, carpet, etc) then one (1) specimen being a minimum size of
approximately 1000x500 mm is required

Date:	9/02/2022	n°:
Address:	Factory 3 Spray Avenue Mordialloc	46
Client:	Signorino	
Name:	Josh	
Test Method:	Wet Pendulum Testing, AS 4586-2013	
Slider Preparation:	Abrasive PaperP400, Pink lapping paper Wet	
Weather:	28	

CONDUCTED BY: LACHLAN COUACAUD	SURFACE: Cream Porcelain (600 x 600mm)
RUBBER SLIDER USED: SLIDER 96	TEST METHOD: WESSEX PENDULUM SKID TESTER


PRODUCT PHOTO:	Picture:	Condition: PRIOR TESTING.
		

PRIOR TREATMENT

SPECIMENT NUMBER:	Location	CONDITION	DIRECTION OF TESTS	MEAN BPN LAST THREE SWINGS
1	Tile	As Found	Anticipated Direction of Pedestrian Traffic	18
2	Tile	As Found	Anticipated Direction of Pedestrian Traffic	15
3	Tile	As Found	Anticipated Direction of Pedestrian Traffic	16
	Mean BPN SRV			
	Classification:	P1	Result:	16

Report of Procedure:

PROCEDURE:	Anti Slip
CHEMICAL USED:	Anti Slip
SEALED WITH:	Rockstar Natural Finish Sealer

PRODUCT PHOTO:	Picture:	Condition: AFTER TREATMENT
		

POST TREATMENT				
SPECIMENT NUMBER:	Location	CONDITION	DIRECTION OF TESTS	MEAN BPN LAST THREE SWINGS
1	Tile	As Found	Anticipated Direction of Pedestrian Traffic	47
2	Tile	As Found	Anticipated Direction of Pedestrian Traffic	48
3	Tile	As Found	Anticipated Direction of Pedestrian Traffic	48
	Mean BPN SRV			
	Classification:	P4	Result:	48

CONCLUSION:

Tile achieved desired result with no further work.

Class	Pendulum SRV	
	Slider 96	Slider 55
P5	>54	>44
P4	45-54	40-44
P3	35-44	35-39
P2	25-34	20-34
P1	12--24	<20
P0	<12	